

MCL Coliform Violation (TCR 22)

The **SPRINGMONT SUBDIVISION PWS 1010255** water system collected **two** water samples during **MAR 2015**, that contained coliform bacteria. This water system is required to submit a minimum of two routine water samples each month for bacteriological analysis. One routine sample was coliform-found and one repeat sample was coliform-found.

The Texas Commission on Environmental Quality (TCEQ) sets drinking water standards in Texas and has determined that the presence of total coliform is a possible health concern. Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful, bacteria may be present. Coliforms were found in more samples than allowed and this was a warning of potential problems.

For water systems analyzing at least 40 samples per month, no more than five (5) percent of the monthly samples may be positive for total coliform. For systems analyzing fewer than 40 samples per month, no more than one (1) sample per month may be positive for total coliform.

What is being done?

Corrective action: We collected additional repeat samples, and all were total coliform free, so we were no longer in violation.

If you have questions regarding this matter, you may contact:

Water System Official: \_\_Undine Texas, LLC. \_\_

Area code + phone number: \_713-559-6878 or 888-201-4314\_\_

Date posted: \_\_2-26-2020\_\_\_\_\_

*\*Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail. \**

-----